

## Legend

Marker	conditions 1	Condition 2	Condition 3
Nitrates	Less than 9	Between 9 and 10	Greater than 10
Chloride	Between 0 and 250	Greater than 250	
Cadmiu m	Less than or equal to .005	Greater than 0.005	
Chromiu m	Less than or equal to .05	Greater than 0.05	
Lead	Less than .01	Greater than 0.01	
Hardness ( Calc)	Less than 200	Between 200 and 500	Greater than or equal 500

(1) Note no's with .005 = below detection limit

(2) Note no's with .05 = below detection limit

(3) Note no's with 0 = below detection limit

Sample #	Location	Date	Civic Address	City sample loc.	Sampler's Name	Lab approval	Date Approved	Nitrate-N
232356	Summerside Fire Department	Jan 13 2009	251 Foundry	6	RI	Janna Dingwell	Jan 13 2008	3.40
232362	Wilmot Well Field #2	Jan-13-09	855 Read Dr.	8.0	RI	Janna Dingwell	Jan 13 2008	3.20
232777	Summerside Fire Hall #1	Feb-02-09	251 Fouundry St.	6	RI	Janna Dingwell	Feb 4 2009	4.50
232779	Bens Bakery	Feb-02-09	686 water St.	7	RI	Janna Dingwell	Feb 4 2009	6.80
232783	Wilmot Well Field	feb-02-09	855 Read Dr.	8	RI	Janna Dingwell	Feb 4 2009	6.80
233147	Summerside Fire Hall #1	feb-17-09	251 Fouundry St.	6	RI	Janna Dingwell	Feb 19 2009	3.10
233149	Bens Bakery	feb-17-09	686 water St.	7	RI	Janna Dingwell	Feb 19 2009	5.80
233153	Wilmot Well Field	feb-17-09	855 Read Dr.	8	RI	Janna Dingwell	Feb 19 2009	5.70
233471	Wilmot Well Field #	Mar-6-09	855 Read Dr.	8	RI	Jana Dingwell	Mar-6-2009	5.90
233465	Summerside Fire Hall	Mar-6-09	251 foundry St.	6	RI	Jana Dingwell	Mar-4-2009	3.00
233467	Bens Bakery	Mar-6-09	686 Water st East	7	RI	Jana Dingwell	Mar-6-2009	5.70
233892	Summerside Fire Hall	Mar-17-09	251 foundry St.	6	RI	Jana Dingwell	Mar-25-09	2.90
233891	Wedgewood Manor	Mar-17-09	310 Brophy Avenue	4	RI	Jana Dingwell	Mar-25-09	13.30
233898	Wilmot Well Field	Mar-17-09	855 Read Dr.	8	RI	Jana Dingwell	Mar-25-09	5.90
234284	Summerside Fire Hall	Apr-01-09	251 foundry St.	6	RI	Jana Dingwell	Apr-6-09	2.90
234286	Bens Bakery	Apr-01-09	686 Water Street	7	RI	Jana Dingwell	Apr-6-09	4.20
234290	Wilmot Well Field	Apr-01-09	855 Read Dr.	8	RI	Jana Dingwell	Apr-6-09	5.90
234559	Summerside Fire Hall	Apr-14-09	251 foundry St.	6	RI	Jocelyn Robbins	Apr-16-09	3.20
234565	Wilmot Well Field Gallery	Apr-14-09	855 Read Dr.	8	RI	Jocelyn Robbins	Apr-16-09	6.00
235101	Summerside Fire Hall	Apr-30-09	251 foundry St.	6	RI	Jocelyn robbins	May-5-09	3.19
235103	Bens Bakery Store	Apr-30-09	686 Water Street	7	RI	Jocelyn robbins	May-5-09	5.94
235107	Wilmot Well Field	Apr-30-09	855 Read Dr.	8	RI	Jocelyn robbins	May-5-09	5.70
235742	Wilmot Well Gallery	May-12-09	855 Read Drive	8	RI	Lori Connolly	May-14-09	5.80
235738	Ben's Bakery	May-12-09	686 Water Street	7	RI	Lori Connolly	May-14-09	5.70
235736	Summerside Fire Hall	May-12-09	251 Foundry Street	6	RI	Lori Connolly	May-14-09	3.10
236511	Summerside Fire Hall	May-26-09	251 foundry St.	6	RI	Jocelyn Robbins	Jun-2-09	3.10
236519	Briggs Street Well	May-26-09	Briggs Street	1	RI	Jocelyn Robbins	Jun-2-09	5.60
236517	Wilmot Well Field Gallery	May-26-09	855 Read Dr.	8	RI	Jocelyn Robbins	Jun-2-09	3.37
237064	Wilmot Well 3	June-2-09	855 Read Dr.	8	RI	Jocelyn Robbins	Jun-4-09	8.42
237373	Summerside Fire Hall	June-8-09	251 foundry St.	6	RI	Jocelyn Robbins	June-9-09	6.30
237375	Bens Bakery Store	June-8-09	686 Water Street	7	RI	Jocelyn Robbins	June-9-09	5.20
237379	Wilmot Well Field Gallery	June-8-09	855 Read Dr.	8	RI	Jocelyn Robbins	June-9-09	3.20

## Legend

Marker	Condition 1	Condition 2	Condition 3
Nitrates	Less than 9	Between 9 and 10	Greater than 10
Chloride	Between 0 and 250	Greater than 250	
Cadmiu m	Less than or equal to .005	Greater than 0.005	
Chromiu m	Less than or equal to .05	Greater than 0.05	
Lead	Less than .01	Greater than 0.01	
Hardness ( Calc)	Less than 200	Between 200 and 500	Greater than or equal 500

(1) Note no's with .005 = below detection limit

(2) Note no's with .05 = below detection limit

(3) Note no's with 0 = below detection limit

Sample #	Location	Date	Civic Address	City sample loc.	Sampler's Name	Lab approval	Date Approved	Nitrate-N
238460	Summerside Fire Hall	June-22-09	251 foundry St.	6	RI	Janna Dingwell	June-25-09	3.07
238462	Bens Bakery Store	June-22-09	686 Water Street	7	RI	Janna Dingwell	June-25-09	6.21
238466	Wilmot Well Field Gallery	June-22-09	855 Read Dr.	8	RI	Janna Dingwell	June-25-09	5.98
239363	Bens Bakery Store	July-2-09	686 Water Street	7	JM	Jocelyn Robbins	July-8-09	7.40
239367	Wilmot Well Field Gallery	July-2-09	855 Read Dr.	8	RI	Jocelyn Robbins	July-8-09	7.70
241969	Wilmot Well Field Gallery	Aug-4-09	855 Read Dr	8	RI	Jocelyn Robbins		5.90
243381	Summerside Fire Hall	Aug-19-09	251 foundry St.	6	RI	Jackie Garnhum	Aug-26-09	3.30
243383	Bens Bakery Store	Aug-19-09	686 Water Street	7	RI	Jackie Garnhum	Aug-26-09	7.80
243387	Wilmot Well Field Gallery	Aug-19-09	855 Read Dr.	8	RI	Jackie Garnhum	Aug-26-09	7.60
244051	Summerside Fire Hall	Sept-1-09	251 foundry St.	6	RI	Jackie Garnhum	Sept-4-09	3.10
244053	Bens Bakery Store	Sept-1-09	686 Water Street	7	RI	Jackie Garnhum	Sept-4-09	7.30
244057	Wilmot Well Field Gallery	Sept-16-2008	855 Read Dr.	8	RI	Jackie Garnhum	Sept-4-09	7.40
244968	Wilmot Well Field Gallery	Sept-16-09	855 Read Dr.	8.00	RI	Jackie Garnhum	Sept-21-09	5.30
244964	Tims reads Corner	Sept-16-09	Water Street East	8.00	RI	Jackie Garnhum	Sept-21-09	7.90
244962	Summerside Fire Hall	Sept-16-09	251 foundry St.	6.00	RI	Jackie Garnhum	Sept-21-09	3.20
245627	Summerside Fire Hall	Sept-29-09	251 Foundry Street	6.00	RI	Jackie Garnhum	Oct-6-09	3.00
245629	Bens Bakery Store	Sept-29-09	686 Water Street	7.00	RI	Jackie Garnhum	Oct-6-09	7.00
245633	Wilmot Well Field Gallery	Sept-29-09	855 Read Dr.	8.00	RI	Jackie Garnhum	Oct-6-09	7.70
246381	Summerside Fire Hall	Oct-14-09	251 Foundry Street	6.00	RI	Jackie Garnhum	Oct-19-09	3.10
246383	Bens Bakery	Oct-14-09	686 Water Street	7.00	RI	Jackie Garnhum	Oct-19-09	5.00
246387	Wilmot well field Gallery	Oct-14-09	855 Read Dr.	8.00	RI	Jackie Garnhum	Oct-19-09	3.60
246961	Wilmot Well field	oct-28-09	855 Read Dr.	8.00	RI	Jana Dingwell	Nov-20-09	8.20
246957	Bens Bakery	oct-28-09	686 Water St.	7.00	RI	Jana Dingwell	Nov-20-09	7.70
246955	Summerside Fire Hall	oct-28-09	251 Foundry St.	6.00	RI	Jana Dingwell	Nov-20-09	3.30
246962	Greenwood Drive Well	oct-28-09	Greenwood Drive	2.00	RI	Jana Dingwell	Nov-20-09	3.80
247463	Bens Bakery	Nov-9-09	686 Water Street	7.00	RI	Jana Dingwell	Nov-19-09	8.20
247461	Summerside Fire Hall	Nov-9-09	251 Foundry st.	6.00	RI	Jana Dingwell	Nov-19-09	3.15
247467	Wilmot Well Field Gallery	Nov-9-09	855 Read Drive	8.00	RI	Jana Dingwell	Nov-19-09	8.40
248022	Summerside Fire Hall	Nov-24-09	251 Foundry St.	6.00	RI	Jana Dingwell	Nov-29-09	3.20
248028	Wilmot Well Field Gallery	Nov-24-09	855 Read Dr.	8	RI	Jana Dingwell	Nov-29-09	8.30
248024	Ben's Bakery	Nov-24-09	686 Water St East	7	RI	Jana Dingwell	Nov-29-09	5.90
248467	Wilmot Well Field	Dec-8-09	855 Read dr	8	RI	Jana Dingwell	Dec-11-09	6.40

## Legend

Marker	conditions 1	Condition 2	Condition 3
Nitrates	Less than 9	Between 9 and 10	Greater than 10
Chloride	Between 0 and 250	Greater than 250	
Cadmiu m	Less than or equal to .005	Greater than 0.005	
Chromiu m	Less than or equal to .05	Greater than 0.05	
Lead	Less than .01	Greater than 0.01	
Hardness ( Calc)	Less than 200	Between 200 and 500	Greater than or equal 500

(1) Note no's with .005 = below detection limit

(2) Note no's with .05 = below detection limit

(3) Note no's with 0 = below detection limit

Sample #	Location	Date	Civic Address	City sample loc.	Sampler's Name	Lab approval	Date Approved	Nitrate-N
248461	Summerside Fire Hall	Dec-8-09	251 Foundry Street	6	RI	Jana Dingwell	Dec-11-09	3.10
248463	Bens Bakery	Dec-8-09	686 Water Street	7	RI	Jana Dingwell	Dec-11-09	5.60
248951	Summerside Fire Hall	Dec-22-09	251 Foundry Street	6	RI	Jocelyn Robbins	Dec-29-09	3.20
248953	Bens Bakery	Dec-22-09	686 Water Street	7	RI	Jocelyn Robbins	Dec-29-09	5.90
248957	Wilmot Well Field Gallery	Dec-22-09	855 Read dr	8	RI	Jocelyn Robbins	Dec-29-09	7.00